

APAVE SUDEUROPE SAS
LABORATOIRE DE LYON TASSIN
Accredited body by COFRAC n° 1-1461
177, route de Sain-Bel
69160 TASSIN LA DEMI-LUNE

ERICO
B.P. 31
Rue Charles Dallière
42161 ANDREZIEUX Cedex

SYNTHESIS DOCUMENT

CONFORMITY ASSESSMENT OF TOTAL INSULATION OF FLEXIBLE BARS ERIFLEX (CLASS II)

1 SCOPE OF THIS DOCUMENT

The present document constitutes the synthesis of the APAVE report n° 6479864-001-3 which gives the details of inspections and tests achieved on the product.

2 CONCERNED PRODUCT SPECIFIED FEATURE

- | | | | |
|-----------|----------------|--------------------------------|---------------------------------|
| • Name : | Flexibles bars | | |
| • Make : | ERIFLEX | • Rated voltage : | 1000 V |
| • Model : | FLEXIBAR | • Neutral position (class II): | TN and TT - 830 V
IT - 600 V |

3 SCOPE OF THE MISSION (to see details in report)

Conformity Assessment of reinforced insulation of the product in reference to the corresponding requirements defined in the standard:

⇒ NF EN 61439-1 (2012) / IEC 61439-1 (2011).

CONCLUSION OF THE REPORT

The conclusion of the report shows that the examined product is in compliance with the prescriptions of the reference documents.

The characterization as a reinforced insulation for ERIFLEX bars notably allows considering that, for article 8.6.4, there is no additional requirement according to table 4: hence the 80% ratio is not applicable.

Tassin the 26/05/2016

Charge of Development mission
Document original immatériel



Limit of validity of this document : 5 years

Xavier SCHMITT

This document is not a report established under the title of a Notified body, it is a synthesis of the mission achieved by APAVE and only the complete French report maybe used as reference. It doesn't substitute itself to the DECLARATION OF CONFORMITY issued by the manufacturer, according the market regulation of the EUROPEAN UNION and cannot be use as a guarantee of the production conformity to the type.
Its reproduction is only allowed as a complete photographic facsimile