



APAVE SUDEUROPE SAS
LABORATOIRE DE LYON TASSIN
Accredited body by COFRAC n° 1-1461
177, route de Sain-Bel
69160 TASSIN LA DEMI-LUNE

ERICO
B.P 31
Rue Charles Dallière
42161 ANDREZIEUX Cedex

SYNTHESIS DOCUMENT
CONFORMITY ASSESSMENT OF TOTAL INSULATION OF ERIFLEX
INSULATED BRAID RANGE, Type ERIFLEX IBS IBSB ADVANCED
(CLASS II)

1 SCOPE OF THIS DOCUMENT

The present document constitutes the synthesis of the APAVE report n° 10075936-001-1 which gives the details of inspections and tests achieved on the range of product.

2 CONCERNED PRODUCT

SPECIFIED FEATURE

- | | |
|--|--|
| <ul style="list-style-type: none">• Name : Range of insulated braided conductor ERIFLEX IBS IBSB ADVANCED• Designation : INSULATED BRAID• Make : ERICO• Model : ERIFLEX IBS, IBSB, ADVANCED | <ul style="list-style-type: none">• Voltage : 1000Vac / 1500Vdc• Neutral position : all• Serial number : / |
|--|--|

3 SCOPE OF THE MISSION (to see details in report)

Conformity Assessment of the range of product and its technical file to the following documents :

⇒ § 8.4.4. of NF EN 61439-1 (2012) / IEC 61439-1 (2011)

CONCLUSION OF THE REPORT

The conclusion of the report shows that the examined product is in compliance with the prescriptions of the reference documents.

Tassin the 2018/02/16

The technical Manager of Testing laboratory

Limit of validity of this document : 5 years

Xavier SCHMITT

Document original immatériel

This document is not a report established under the title of a Notified body, it is a synthesis of the mission achieved by APAVE and only the complete French report maybe used as reference. It doesn't substitute itself to the DECLARATION OF CONFORMITY issued by the manufacturer, according the market regulation of the EUROPEAN UNION and cannot be use as a guarantee of the production conformity to the type.
Its reproduction is only allowed as a complete photographic facsimile